

**Cowichan Valley Regional District  
Cherry Point Water - Manganese (Mn) Results Summary**

<i>Sampling Date</i>	<i>UNITS</i>	<i>MAC</i>	<i>AO</i>	<i>Total Mn-Distribution</i>	<i>Sampling Location:</i>
Thursday, May 2, 2013	mg/L	0.12	0.02	0.0180	S1-Lot 15 Paradise Close
Tuesday, May 5, 2015	mg/L	0.12	0.02	0.0803	S1-Lot 15 Paradise Close; Well-tap on inlet from well in TB
Thursday, October 19, 2017	mg/L	0.12	0.02	0.0453	S1-Lot 15 Paradise Close; Well-tap on inlet from well in TB
Tuesday, June 11, 2019	mg/L	0.12	0.02	0.055	S1-Lot 15 Paradise Close
Thursday, October 28, 2021	mg/L	0.12	0.02	0.044	S1-Lot 15 Paradise Close
Tuesday, January 17, 2023	mg/L	0.12	0.02	0.0681	S4-Reservoir Outlet (Distribution)
Saturday, March 11, 2023	mg/L	0.12	0.02	0.114	S4-Reservoir Outlet (Distribution)
Thursday, July 20, 2023	mg/L	0.12	0.02	0.1200	S4-Reservoir Outlet (Distribution)
Thursday, July 20, 2023	mg/L	0.12	0.02	0.0803	S4-Reservoir Outlet (Distribution)

MAC = Maximum Allowable Concentration

AO = Aesthetic Objective