

# CHERRY POINT ESTATES WATER SYSTEM

## Manganese

			<i>Sample ID</i>	s4-Reservoir Outlet (WTX 24B43)	S4-RESERVOIR OUTLET (WTX 27B43)	S4-RESERVOIR OUTLET (WTX 27B43)	S4-Reservoir Outlet (WTX 27B43)
			<i>Sampling Date</i>	01/17/23	04/11/23	07/20/23	10/16/23
			<i>Sampling Time</i>	11:50 AM	10:30 AM	11:45 AM	10:55 AM
<i>Parameter Name</i>	<i>MAC</i>	<i>AO</i>	<i>Units</i>	<i>Result</i>	<i>Result2</i>	<i>Result3</i>	<i>Result4</i>
Total Manganese (Mn)	120	20	ug/L	<b>68.1</b>	<b>114</b>	<b>101</b>	<b>80.3</b>