

**Cowichan Valley Regional District**  
**Cherry Point Estates Water System - Manganese (Mn) Results Summary**  
**2017 to 2024**

Sampling Date	UNITS	MAC	AO	Total Mn - Distribution	Sampling Location
Tuesday, April 2, 2024	ug/L	120	20	43.4	S1 - 1108 Paradise Cl
Tuesday, April 2, 2024	ug/L	120	20	64.3	S4 - Reservoir Outlet
Tuesday, January 9, 2024	ug/L	120	20	65.1	S4 - Reservoir Outlet
Tuesday, January 9, 2024	ug/L	120	20	95.4	S1 - 1108 Paradise Cl
Monday, October 16, 2023	ug/L	120	20	80.3	S4 - Reservoir Outlet
Thursday, July 20, 2023	ug/L	120	20	101	S4 - Reservoir Outlet
Thursday, July 20, 2023	ug/L	120	20	110	S1 - 1108 Paradise Cl
Tuesday, April 11, 2023	ug/L	120	20	114	S4 - Reservoir Outlet
Tuesday, January 17, 2023	ug/L	120	20	68.1	S4 - Reservoir Outlet
Thursday, October 28, 2021	ug/L	120	20	44	S1 - 1108 Paradise Cl
Tuesday, June 11, 2019	ug/L	120	20	55	S1 - 1108 Paradise Cl
Thursday, October 19, 2017	ug/L	120	20	45.3	S1 - 1108 Paradise Cl
Tuesday, November 15, 2022	ug/L	120	20	136	Well - Tap on Inlet from well in TB
Tuesday, December 15, 2020	ug/L	120	20	132	Well - Tap on Inlet from well in TB
Thursday, June 14, 2018	ug/L	120	20	206	Well - Tap on Inlet from well in TB
Thursday, October 19, 2017	ug/L	120	20	159	Well - Tap on Inlet from well in TB

**MAC: Maximum Allowable Concentration**

**AO: Aesthetic Objective**